



**BUREAU  
VERITAS**

# Certificate of compliance

**Applicant:** **Renac Power Technology Co., Ltd**  
Building 6, No.2, West Jinzhi Road, High-Tech District  
Suzhou City, Jiangsu Province  
China

**Product:** **Photovoltaic inverter**

**Model:** **R3-4K-DT  
R3-5K-DT  
R3-6K-DT  
R3-8K-DT  
R3-10K-DT  
R3-12K-DT  
R3-15K-DT**

## Use in accordance with regulations:

The inverters are tested according to electrical safety, grid protection, specified environmental influences and efficiency. For detailed information, please watch the corresponding test reports.

## Applied rules and standards:

IEC 61727:2004 Characteristics of the utility interface  
IEC 62116:2014 Islanding prevention measures for utility-interconnected photovoltaic inverters.  
IEC 60068-2-1:2007 Environmental testing – Part 2-1: Tests – Test A: Cold  
IEC 60068-2-2:2007 Environmental testing – Part 2-2: Tests – Test B: Dry heat  
IEC 60068-2-14:2009 Environmental testing – Part 2-14: Tests – Test N: Change of temperature  
IEC 60068-2-30:2005 Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12h + 12 h cycle)  
IEC 61683:1999 Photovoltaic systems – Power conditioners – Procedure for measuring efficiency

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** **ABRE-18SE0642FCSHP-1-R1  
ABRE-18SE0642FCSHP-2-R1  
ABRE-18SE0642FCSHP-3-R1  
ABRE-18SE0642FCSHP-4-R1**

**Certificate number:** **U20-0295**

**Date of issue:** **2020-04-23**

## Certification body

Thomas Lammel

Certification body Bureau Veritas Consumer Products Services Germany GmbH accreditation to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written approval of Bureau Veritas Consumer Products Services Germany GmbH